fencing if provided. Attach additional sheets as needed.

OK NO* N\A	
LOCATION AND ASSEMBLY	
	Ground surface is stable, level, and hazard free.
	Located minimum 50' from building exits.
	Located minimum 20' from buildings.
	Located to not block area fire safety equipment, fire lane,
	or maintenance access to any area or features.
	Located with adequate clearance to other temporary
	structures.
	Located a minimum of 10' from adjacent temporary
	structures.
	Structure is adequate supported and anchored. Staking
	only permitted where preapproved.
	Structure assembly is sounds and utilizes standard
	manufactures connection methods. FIRE SAFETY
	Fire Retardancy verified by label, certificate, or applied treatments.
	No smoking permitted and posted as needed.
	Grounds are clear of dry vegetation and combustible
	decorations are not excessive.
	No open flames permitted.
HHH	Fire extinguisher provided where required.
	Occupancy limit posted if >50 occupants.
	No cooking in the structure open for guest use.
	Cooking with grease laden vapors or flame not permitted
	in any temporary structure.
	Heat or fuel fired appliances minimum 10' from structure.
	Provide barrier to hot surfaces.
	Proper utility connections provided.
EGRESS	
	Exits properly located.
	Exits signs/placards provided where required.
	Emergency lighting provided where required.
	Adequate normal use lighting provided.
MISCELLANEOUS	
	Public announcement system provided where required.
	Damages to grounds not incurred with delivery or removal.

Check if attachments Comments: Approved with Comment\_\_\_\_ Approved for Occupancy \_\_\_\_ Re-inspection Required \_\_\_\_ Disapproved\_\_\_\_ Tent Inspected by: Date:

Sketch the site plan and structure(s) here. Include the closest adjacent buildings, sidewalks, driveways, etc. with dimensions in feet. The structure details must indicate dimensions, exit openings, stake lines and site

\*EXPLAIN ALL "NO" IN COMMENT SECTION